

Certificate

Certificate No: 18415/10

Issue No: 2

Date of issue: 28 April 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Ventilator Details

Ventilator Supplier	Nuaire Ltd
Ventilator Model	SQUIF 43-1
Ventilator Serial Number	0875917

Motor Details

Motor Manufacturer	Leroy Somers
Motor Model	LS90P/T
Motor Serial Number	401372-2004

Test Conditions

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2
Application Classes	Uninsulated Non Smoke Reservoir Dual Purpose Ducted Cooling Air Required? No
Date of test	16/02/2005

Certificate Details

Client	Nuaire Ltd
Client Address	Western Industrial Estate, Caerphilly, CF83 1NA, UK
Date of issue	28/04/2009
Date of expiry	28/04/2009

Quality Approved

Philip Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 18415/10, available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

