

# Certificate

**Certificate No: 18415/11**
**Issue No: 2**
**Date of issue: 28 April 2009**

This is to certify that

**BSRIA Limited**

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

**Ventilator Details**

Ventilator Supplier	Arem SA
Ventilator Model	CELN560GF/34N
Ventilator Serial Number	900050

**Motor Details**

Motor Manufacturer	Leroy Somer
Motor Model	3 ~ LS100LT, 2.2 kW
Motor Serial Number	GP10203RJ029

**Test Conditions**

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2
Application Classes	Uninsulated Non Smoke Reservoir Dual Purpose Ducted Cooling Air Required? No
Date of test	03/03/2005

**Certificate Details**

Client	Nuair Ltd
Client Address	Western Industrial Estate, Caerphilly, CF83 1NA, UK
Date of issue	28/04/2009
Date of expiry	28/04/2012

**Quality Approved**

Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 18415/11, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.

