

# Certificate

Certificate No: 18415/2

Issue No: 2

Date of issue: 28 April 2009

This is to certify that

## BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

### Ventilator Details

Ventilator Supplier	Nuaire
Ventilator Model	AX45D-213A7Z
Ventilator Serial Number	0852299

### Motor Details

Motor Manufacturer	Leroy Somer
Motor Model	LSHT80L
Motor Serial Number	609913 RG002

### Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 Hours
Application Classes	Uninsulated Smoke Reservoir Dual Purpose Ducted Cooling Air Required? No
Date of test	23/09/2004

### Certificate Details

Client	Nuaire Ltd
Client Address	Western Industrial Estate, Caerphilly, CF83 1NA, UK
Date of issue	28/04/2009
Date of expiry	28/04/2012

**Quality Approved** Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 18415/2, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.



1053