

Certificate

Certificate No: 18415/3

Issue No: 2

Date of issue: 28 April 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Ventilator Details

Ventilator Supplier	Nuaire
Ventilator Model	AX63AD-243A7Z
Ventilator Serial Number	0855705

Motor Details

Motor Manufacturer	Leroy Somer
Motor Model	LSHT160L-T
Motor Serial Number	63293 RH001

Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 Hours
Application Classes	Uninsulated Smoke Reservoir Dual Purpose Ducted Cooling Air Required? No
Date of test	30/09/2004

Certificate Details

Client	Nuaire Ltd
Client Address	Western Industrial Estate, Caerphilly, CF83 1NA, UK
Date of issue	28/4/2009
Date of expiry	28/4/2012

Quality Approved

Philip Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 18415/3 Edition 2, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.



This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: bsria@bsria.co.uk W: www.bsria.co.uk