

# Certificate

**Certificate No: 18415/6**
**Issue No: 2**
**Date of issue: 28 April 2009**

This is to certify that

**BSRIA Limited**

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

**Ventilator Details**

|                          |               |
|--------------------------|---------------|
| Ventilator Supplier      | Nuaire        |
| Ventilator Model         | AX125CY-413A7 |
| Ventilator Serial Number | 0864131       |

**Motor Details**

|                     |              |
|---------------------|--------------|
| Motor Manufacturer  | Leroy Somer  |
| Motor Model         | LSHT160L-T   |
| Motor Serial Number | 632933 RH001 |

**Test Conditions**

|                          |   |
|--------------------------|---|
| BS EN 12101-3 Test Class | F300  |
| Test Temperature         | 300   |
| Test Time (Hours)        | 2 Hours   |
| Application Classes      | Uninsulated<br>Smoke Reservoir<br>Dual Purpose<br>Ducted Cooling Air Required? No |
| Date of test             | 02/12/2004  |

**Certificate Details**

|                |   |
|----------------|---|
| Client         | Nuaire Ltd  |
| Client Address | Western Industrial Estate, Caerphilly, CF83 1NA, UK |
| Date of issue  | 28/04/2009  |
| Date of expiry | 28/04/2009  |

**Quality Approved**

Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 18415/6, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.



1053

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W: [www.bsria.co.uk](http://www.bsria.co.uk)