

# Certificate

**Certificate No: 18415/7**

**Issue No: 2**

**Date of issue: 28 April 2009**

This is to certify that

**BSRIA Limited**

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

**Ventilator Details**

Ventilator Supplier	Nuaire Ltd
Ventilator Model	SQUIF 41-1
Ventilator Serial Number	0861413

**Motor Details**

Motor Manufacturer	Leroy Somers
Motor Model	LS71P/T
Motor Serial Number	421038-2004

**Test Conditions**

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2
Application Classes	uninsulated Non Smoke Reservoir Dual Purpose Ducted Cooling Air Required No
Date of test	02/02/2005

**Certificate Details**

Client	Nuaire Ltd
Client Address	Western Industrial Estate, Caerphilly, CF83 1NA, UK
Date of issue	28/04/2009
Date of expiry	28/04/2012

**Quality Approved**

Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 18415/7, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.



This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

E: [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W: [www.bsria.co.uk](http://www.bsria.co.uk)