

Certificate

www.bsria.co.uk

Certificate No: C18705/2 Ed.2

Issue No: 3

Date of issue: 31 March 2010

This is to certify that

BSRIA Limited

has tested a sample of the product described below in accordance with the test methods contained within *BS EN 1858:2003* and have determined the system chimney product has met the requirements of *BS EN 1858:2003*. For further details see page 2 of this certificate.

Manufacturer/Agent	Dunbrik (Yorks) Ltd. Ferry Lane Stanley Wakefield WF3 4LT
Product	Mini Clearflow Gas flue Block system jointed with 1581 Flue Block Silicone Sealant incorporating Blakbord Insulation Panel.
Test completion date	1 December 2004
Expiry date	31 March 2013
Test Engineer	David Butler

Quality Approved

Dr Fiona Lowrie
MicroClimate & Test

This Certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

1 of 2

E: bsria@bsria.co.uk W: www.bsria.co.uk

PRODUCT DETAILS

Product designation
EN1858 T250 N1 D 1 O(75)

TEST RESULTS**Table 1 Findings of examination for compliance with BS EN 1858 : 2003**

BSEN1443 CLAUSE	BSEN1858 CLAUSE	TITLE	COMPLIES?
-	4	Materials and designations of flue blocks	Yes
-	5	Reinforcement	N/a
-	6	Surface treatment	N/a
5	7	Form, dimensions and tolerances	Yes
6.3.1	8.1	Heat stress resistance	Yes
6.3.2	8.2	Heat shock resistance	N/a
4.8	8.3	Thermal resistance	N/a
6.4.1	8.4	Gas tightness	Yes
-	8.5	Abrasion resistance	Yes
6.2	8.6	Compressive strength	Yes
4.5 & 6.4.3	8.7	Corrosion resistance	N/a
4.4	8.8	Condensate resistance	N/a
-	8.9	Bulk density	Yes
6.2	8.10	Flexural strength under wind loading	N/a
6.7.5	8.11.1	Flow resistance of flue blocks (assume data obtained from EN 13384-1)	N/a
6.7.5	8.11.2	Flow resistance of fittings (assume data obtained from EN 13384-1)	N/a
4.9	8.12	Freeze-thaw resistance	N/a
4.11	9	Designation	Yes
7.2	10	Marking	Yes
7.4	11	Production information	Yes