

# Certificate

Certificate No: 19114/1 Edition 2

Issue No: 2

Date of issue: 2 September 2009

This is to certify that

## BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

### Ventilator Details

Ventilator Supplier	Elta Fans Ltd
Ventilator Model	JVSU-CPA-400 2/4-3
Ventilator Serial Number	132490

### Motor Details

Motor Manufacturer	Weg
Motor Model	3 ~ 80-2/4, 1.3 kW
Motor Serial Number	GP55401

### Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2
Application Classes	Uninsulated Smoke Reservoir Dual Purpose Ducted Cooling Air Required? No
Date of test	10/05/05

### Certificate Details

Client	Elta Fans Ltd
Client Address	17 Barnes Wallis Road, Fareham, Hampshire PO15 5ST
Date of issue	2 September 2009
Date of expiry	2 September 2012

### Quality Approved

Phil Stonard  
Laboratory Manager  
Testing & Certification



This certificate supersedes Certificate No. 19114/1 dated June 28 2005. Full details are shown in BSRIA Report Number 19114/1 Edition 2, available from the client. To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W: [www.bsria.co.uk](http://www.bsria.co.uk)