

Certificate

Certificate No: 19170/13
Issue No: 2
Date of issue: 2 September 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Ventilator Details

Ventilator Supplier	Elta Fans Ltd
Ventilator Model	LCS090R4-A12/31/B
Ventilator Serial Number	137002

Motor Details

Motor Manufacturer	Leroy Somer
Motor Model	FLSHT 160M4 B3
Motor Serial Number	90770800SC01

Test Conditions

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2 hr
Application Classes	Uninsulated Smoke reservoir Dual purpose Ducted cooling air required? No
Date of test	25 January 2006

Certificate Details

Client	Elta Fans
Client Address	17 Barnes Wallis Rd, Fareham, Hampshire PO15 5ST
Date of issue	2 September 2009
Date of expiry	2 September 2012

Quality Approved

Phil Stonard
Laboratory Manager
Testing & Certification



1053

Full details are shown in BSRIA Report Number 19170/13, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: bsria@bsria.co.uk W: www.bsria.co.uk