

Certificate

Certificate No: 19183/9
Issue No: 2
Date of issue: 6 November 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Ventilator Details

Ventilator Supplier	London Fan Company
Ventilator Model	CL1250S04C08AAT
Ventilator Serial Number	218320

Motor Details

Motor Manufacturer	WEG
Motor Model	3~200L-4, 45kW
Motor Serial Number	BU18525

Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Uninsulated Smoke reservoir Dual purpose No ducted cooling air required
Date of test	19 December 2005

Certificate Details

Client	The London Fan Company
Client Address	75-81 Stirling Road – LONDON W3 8DJ
Date of issue	6 November 2009
Date of expiry	6 November 2012

Quality Approved Phil Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 19183/9, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: bsria@bsria.co.uk W: www.bsria.co.uk