

# Certificate

Certificate No: 19416/4

Issue No: 2

Date of issue: 28 April 2009

This is to certify that

## BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

### Ventilator Details

Ventilator Supplier	Nuaire
Ventilator Model	AX125CV-453S8
Ventilator Serial Number	0989728

### Motor Details

Motor Manufacturer	WEG
Motor Model	3~280S/M-4, 75 kW (IEC)
Motor Serial Number	OA67062

### Test Conditions

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2 hrs
Application Classes	Uninsulated Smoke reservoir Dual purpose Ducted cooling air required? No
Date of test	23/08/2005

### Certificate Details

Client	Nuaire Ltd
Client Address	Western Industrial Estate Caerphilly CF83 1NA
Date of issue	28/04/2009
Date of expiry	28/04/2012

### Quality Approved

Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 19416/4, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.



This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W: [www.bsria.co.uk](http://www.bsria.co.uk)