

# Certificate

**Certificate No: 19416/7**
**Issue No: 2**
**Date of issue: 28 April 2009**

This is to certify that

**BSRIA Limited**

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

**Ventilator Details**

Ventilator Supplier	Nuaire
Ventilator Model	SVT-1E
Ventilator Serial Number	1026153

**Motor Details**

Motor Manufacturer	WEG
Motor Model	3~80-4/2
Motor Serial Number	GV65889

**Test Conditions**

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Uninsulated Smoke reservoir Dual purpose Ducted cooling air required? No
Date of test	10/11/2005

**Certificate Details**

Client	Nuaire Ltd
Client Address	Western Industrial Estate, Caerphilly, Mid Glamorgan CF83 1NA
Date of issue	28/04/2009
Date of expiry	28/04/2012

Note: The SVT range has been superseded by the SVT2, however many components (including motors and impellers) are common, and the test results remain valid and are used in support of the SVT2 range.

**Quality Approved**

Philip Stonard  
Laboratory Manager  
Testing & Certification

Full details are shown in BSRIA Report Number 19416/7, available from the client.  
To authenticate this certificate, visit [www.bsria.co.uk/certificates](http://www.bsria.co.uk/certificates), or contact BSRIA Limited.



This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

**BSRIA Limited**

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

 E: [bsria@bsria.co.uk](mailto:bsria@bsria.co.uk) W: [www.bsria.co.uk](http://www.bsria.co.uk)