

Certificate

Certificate No: 40084/4 Edition 2

Issue No: 3

Date of issue: 20 October 2010

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	05/09/07
BSRIA Test Item Number	40084B1MAR
Ventilator Details	
Ventilator Manufacturer	Ventispecial
Ventilator Model	CPC 250-S (This unit also marketed under the names "Cyclone CPV 50" "PV 250 S" "CJF 50 F" and "CPC 250-4-S")
Ventilator Serial Number	00278
Motor Details	
Motor Manufacturer	WEG
Motor Model	3~90S-4, 1.5 kW
Motor Serial Number	QC20960
Test Conditions	
BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Centrifugal fan with motor in airstream
Certificate Details	
Client	VentiSpecial BV
Client Address	Postbus 468,5140 AL WAALWIJK, Netherlands
Date of issue	15 November 2010
Date of expiry	15 November 2013

Quality Approved PHIL STONARD
Laboratory Manager
MicroClimate & Test

Full details are shown in BSRIA Report Number 40084/4 Edition 2, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text