

Certificate

Certificate No: 40135/1
Issue No: 2
Date of issue: 28 April 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Ventilator Details

Ventilator Supplier	Nuaire
Ventilator Model	SVT – 2E
Ventilator Serial Number	1122538

Motor Details

Motor Manufacturer	WEG
Motor Model	3~80-4/2, 1.27 kW (AOR, 2 pole))
Motor Serial Number	HA97940

Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Date of test	03/08/2006

Certificate Details

Client	Nuaire Limited
Client Address	Western Industrial Estate, Caerphilly, Mid Glamorgan CF83 1NA
Date of issue	28/04/2009
Date of expiry	28/04/2012

Note: The SVT range has been superceded by the SVT2, however many components (including motors and impellers) are common, and the test results remain valid and are used in support of the SVT2 range.

Quality Approved Philip Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 40135/1, available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.



1053