

Certificate

Certificate No: 51583/1

Issue No: 2

Date of issue: 28 February 2011

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	22/01/08
BSRIA Test Item Number	51583A1MAR
Ventilator Details	
Ventilator Manufacturer	Elta Fans
Ventilator Model	JISU-2-CPC-100N
Ventilator Serial Number	148457
Motor Details	
Motor Manufacturer	WEG
Motor Model	3~90L-8/4
Motor Serial Number	HP64578
Test Conditions	
BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Centrifugal, motor in airstream
Certificate Details	
Client	Elta Fans Ltd
Client Address	17 Barnes Wallis Road, Segensworth East Industrial Estate, Fareham, Hampshire, PO15 5ST
Date of issue	28 February 2011
Date of expiry	28 February 2014

Quality Approved PHIL STONARD
 Laboratory Manager

Full details are shown in BSRIA Report Number 51583/1, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text