

# Certificate

[www.bsria.co.uk](http://www.bsria.co.uk)

**Certificate No: 51611/1 Edition 2 Issue No: 3**

**Date of issue: 17 March 2011**

This is to certify that

**BSRIA Limited (Notified Body 0480)**

have tested a sample of the product described below in accordance with the test methods contained within BSEN 442-1 Annex ZA and have determined the items met the requirements of the EU Construction Products Directive (89/106/CEE). For further details see page 2 of this certificate

**Manufacturer/Agent** Shandong Bantal Radiator Co. Ltd.  
537 Liquan Street  
Gaomi City  
Shandong Province  
China  
Zip: 261500

**Product** Towel Rail (white)

**Trade mark and model** GGZ 736x500

**Date of test** 24 January 2008 to 01 February 2008

**Expiry date:** 17 March 2014

**Test Engineers** P Stonard, Alf Russell

**Quality Approved** Phil Stonard  
Laboratory Manager

This Certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

**PRODUCT DETAILS****Thermal Performance Data**

Product reference	Output at 50 $\Delta T$	Equation of Output	
		Constant ' $k_M$ '	Exponent ' $n$ '
GGZ 736x500	376	2.9333	1.2410

## Mechanical and range data

Reference	Nominal overall size L x H (mm)	Weight (kg)	Water content (kg)	Other designs or models of generic group
GGZ 736x500	500 x 736	6.9	3.6	None