

Certificate

Certificate No: 52454/1

Issue No: 2

Date of issue: 28 April 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	19/09/08
BSRIA Test Item Number	52454A1MAR
Ventilator Details	
Ventilator Manufacturer	Nuaire
Ventilator Model	SVT2-1E
Ventilator Serial Number	1652428
Motor Details	
Motor Manufacturer	WEG
Motor Model	3~80-4/2 1.1 kW
Motor Serial Number	HQ31750
Test Conditions	
BS EN 12101-3 Test Class	F200, F300, Unclassified 300°C 2 hrs
Test Temperature	300
Test Time (Hours)	2
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Form B (air over impeller-motor)
Certificate Details	
Client	Nuaire Limited
Client Address	Western Industrial Estate, Caerphilly, Mid Glamorgan, CF83 1NA
Date of issue	28/04/2009
Date of expiry	28/04/2012

Quality Approved Philip Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 52454/1, available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.



1053

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 426511 F: +44 (0)1344 487575

E: bsria@bsria.co.uk W: www.bsria.co.uk