

Certificate

Certificate No: 52574/1

Issue No: 1

Date of issue: 19 February 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

| | |
|----------------------------|---|
| Date of Test | 23/9/08 |
| BSRIA Test Item Number | 52574A1ME |
| Ventilator Details | |
| Ventilator Manufacturer | Elektrovent |
| Ventilator Model | DUCT-MM 502/4 HT |
| Ventilator Serial Number | 160908 |
| Motor Details | |
| Motor Manufacturer | Electro Adda Spa |
| Motor Model | 3~C80-4/2, 1.1 kw |
| Motor Serial Number | A8010826 |
| Test Conditions | |
| BS EN 12101-3 Test Class | F200 |
| Test Temperature | 200 |
| Test Time (Hours) | 2 hrs |
| Application Classes | Un-insulated Smoke reservoir Dual purpose No ducted cooling air required |
| Test Set-up | Vertical Immersed Form B (air over impeller-motor) |
| Certificate Details | |
| Client | Elektrovent |
| Client Address | Via Del Pozzette 18, Z.I. Levrini, 25080 Soiano del Lago (Bs), Italy |
| Date of issue | 19 February 2009 |
| Date of expiry | 19 February 2012 |

Quality Approved PHIL STONARD
Principal Engineer
MicroClimate & Test

Full details are shown in BSRIA Report Number 52574/1, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 465600 **F:** +44 (0)1344 465626

E: bsria@bsria.co.uk **W:** www.bsria.co.uk