

Certificate

Certificate No: 52794/1

Issue No: 1

Date of issue: 25 March 2009

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	9/12/08
BSRIA Test Item Number	52794A1MAR
Ventilator Details	
Ventilator Manufacturer	Elektrovent
Ventilator Model	Duct-M 352 HT F200
Ventilator Serial Number	Test 08
Motor Details	
Motor Manufacturer	Maraz
Motor Model	M200 MM-102
Motor Serial Number	2008-03030
Test Conditions	
BS EN 12101-3 Test Class	F200
Test Temperature	200
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Form B (air over impeller-motor)

Certificate Details

Client	Elektrovent
Client Address	Via Del Pozzette, 18 Z.I. Levrini 5080 Soiano del Lago (Bs) Italy
Date of issue	25 March 2009
Date of expiry	26 March 2012

Quality Approved PHIL STONARD
Principal Engineer
MicroClimate & Test

Full details are shown in BSRIA Report Number 52794/1, available from the client. To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text

BSRIA Limited

Old Bracknell Lane West, Bracknell, Berkshire RG12 7AH UK

T: +44 (0)1344 465600 **F:** +44 (0)1344 465626

E: bsria@bsria.co.uk **W:** www.bsria.co.uk