

Certificate

Certificate No: 53454/1 Edition 2 Issue No: 1

Date of issue: 5 August 2010

This certificate supersedes Certificate Number 53454/1

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	22/07/09
BSRIA Test Item Number	53454A1MAR

Ventilator Details

Ventilator Manufacturer	Systemair GmbH
Ventilator Model	AXR 710-10/37°-2 (F)
Ventilator Serial Number	0001555440

Motor Details

Motor Manufacturer	Brook Crompton
Motor Model	WP-DF200LGX-P
Motor Serial Number	GD 713656

Test Conditions

BS EN 12101-3 Test Class	F400
Test Temperature	400
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Insulated (to simulate immersion) Form B (air over impeller-motor)

Certificate Details

Client	Systemair GmbH
Client Address	Seehofer Str. 45, D97944 Windischbuch, Germany
Date of issue	5 August 2010
Date of expiry	24 August 2012

Quality Approved Phil Stonard
Laboratory Manager

Full details are shown in BSRIA Report Number 53454/1 Edition 2, available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.