

Certificate

Certificate No: 55006/1

Issue No: 1

Date of issue: 23 March 2011

This is to certify that

BSRIA Limited

has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	08/03/11
BSRIA Test Item Number	55006A1AF
Ventilator Details	
Ventilator Manufacturer	Systemair GmbH
Ventilator Model	AXC 1250-8/18°-4 (B)
Ventilator Serial Number	0002065374
Motor Details	
Motor Manufacturer	CMG
Motor Model	SGA 180L-4, 22 kW
Motor Serial Number	901483/037020
Test Conditions	
BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	2 hrs
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Insulated (to simulate immersion) Form A (air over motor-impeller)

Certificate Details

Client	Systemair GmbH
Client Address	Seehöfer Str. 45, D-97944 Windischbuch, Germany
Date of issue	23 March 2011
Date of expiry	23 March 2014

Quality Approved Philip Stonard
Laboratory Manager
Testing & Certification

Full details are shown in BSRIA Report Number 55006/1, available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.