



Weather Louvre Test

Report 57668/1

Carried out for
Seng Yoon Seng Holdings SDN. BHD

By Andrew Freeth

14 January 2014



Weather Louvre Test

Carried out for:

Seng Yoon Seng Holdings SDN. BHD
No. 46, Jalan Industri PBP 3
Taman Industri Pusat Bandar Puchong
47100 Puchong
Selangor Darul Ehsan
Malaysia

Contract: **Report 57668/1**

Date: **14 January 2014**

Issued by: **BSRIA Limited**
Old Bracknell Lane West,
Bracknell,
Berkshire RG12 7AH UK

Telephone: +44 (0)1344 465600

Fax: +44 (0)1344 465626

E: bsria@bsria.co.uk W: www.bsria.co.uk

Compiled by: Name: Andrew Freeth Title: Senior Test Engineer	Approved by: Name: Mark Roper Title: Principal Test Engineer
--	--

This report must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text.

CONTENTS

- 1 INTRODUCTION.....5
 - 1.1 Test item information5
- 2 TEST METHOD7
 - 2.1 Water penetration7
 - 2.2 Pressure drop7
 - 2.3 Test equipment used7
- 3 RESULTS.....8

APPENDICES

- APPENDIX: A MANUFACTURER'S DRAWING.....10

FIGURES

- Figure 1 Test item 57668A1 (front).....6
- Figure 2 Test item 57668A1 (rear).....6

1 INTRODUCTION

This report concerns tests conducted on a louvre to determine the Rainwater Penetration and the Pressure Drop versus Airflow Curve, with the associated Coefficient of Entry using the test methods contained within EN 13030 : 2001. The work was commissioned by Seng Yoon Seng Holdings SDN. BHD. and was carried out at BSRIA on 29 November to 3 December 2013.

Items received for test

Test Item	BSRIA ID
LV3575	57668A1

1.1 TEST ITEM INFORMATION

Contract	57668
Date	28-11-13
Manufacturer	Seng Yoon Seng Holdings SDN. BHD
Louvre Model	LV3575
Material	Galvanised Steel
Painted	No
Blade Height	948 mm
Blade Width	950 mm
Blade Depth	98mm
Frame Depth	100 mm
No. of Blades	9
Blade Pitch	107 mm (average)
Blade Angle	45° approx.
No. of Banks	1
Guard Type	None
Guard Spacing	N/A
Side Channels	None
Water Drip Tray	No
Blade Orientation	Horizontal

Note: Nominal pitch is 110mm but was reduced slightly for test sample purposes.

Figure 1 Test item 57668A1 (front)




Figure 2 Test item 57668A1 (rear)



2 TEST METHOD

A schematic representation of the rig used during testing



The test comprises of two parts:

2.1 WATER PENETRATION

The weather louvre is subjected to fan driven wind at a speed of 13 m/s and water sprayed as rainfall at a rate of 75 l/h. In addition to the simulated wind and rain, air is drawn through the louvre at various set velocities (0, 0.5, 1.0, 1.5, 2.0, 2.5, 3.0 and 3.5 m/s).

Each test is preceded by a suitable ‘pre-test’ soak which is typically around 30 minutes. Each test is run until the results become stable, and in any case, for a minimum of 30 minutes.

The penetrated water is collected in the collection duct and is measured and recorded against time elapsed.

A range of measurements are taken to give the characteristic curve for the test louvre.

2.2 PRESSURE DROP

For this test, the Aerodynamic Measuring Section (AMS) is separated from the main rig. The louvre is then mounted in the upstream opening of the AMS.

Pressure tappings in the plenum walls of the AMS allow measurement of the static pressure within the plenum during testing. The airflow volume is calculated from the differential pressure at the measuring cones. The plenum has a set of settling screens within to produce even flow through the cones and therefore give accurate reading of the total volume.

By adjusting the fan speed, the total airflow through the system varies and therefore changes the pressure on the louvre under test. A range of measurements are taken to give the characteristic curve for the test louvre.

2.3 TEST EQUIPMENT USED

Test equipment	BSRIA ID	Calibration Expiry Date
Water supply measurement	352	12-1-14
Rain measuring system	353	11-1-14
Airflow cones	364	15-1-14
Micromanometer	502	14-2-14
Scales (water)	1364	8-2-14

3 RESULTS


3.1 RAINWATER PENETRATION

MANUFACTURER Seng Yoon Seng
 MODEL LV3575

Date 29/11/2013
 Contract 57668

Simulated rainfall 75 mm/hr
 Wind speed 13.0 m/s
 louvre height 948 mm
 louvre width 950 mm
 louvre area 0.901 m²

VENTILATION RATE		WATER FLOW RATES		Effectiveness	Class
Volume m ³ /s	Velocity m/s	Supply l/h	Penetrated l/h		
0.00	0.00	93.0	3.7	94.6%	C
0.45	0.50	93.0	7.4	89.0%	C
0.90	1.00	93.0	7.9	88.3%	C
1.35	1.50	93.0	10.1	85.1%	C
1.80	2.00	93.0	12.6	81.3%	C
2.25	2.50	93.0	17.0	74.8%	D
2.70	3.00	93.0	25.3	62.6%	D
3.15	3.50	93.0	34.9	48.3%	D




COEFFICIENT OF ENTRY

MANUFACTURER Seng Yoon Seng
 MODEL LV3575


Date 29/11/2013
 Contract 57668

air temperature 17.3 °C louvre height 948 mm
 barometer 1016 mbar louvre width 950 mm
 air density 1.214 kg/m³ louvre area 0.901 m²

louvre pd Pascals	louvre face velocity		air flow rate		coefficient C _e
	m/s	test m ³ /s	theoretical m ³ /s		
304.0	4.35	3.916	20.159	0.194	
288.0	4.23	3.806	19.621	0.194	
275.0	4.13	3.722	19.173	0.194	
224.0	3.73	3.363	17.304	0.194	
158.0	3.16	2.847	14.533	0.196	
91.0	2.39	2.153	11.029	0.195	
63.0	1.99	1.793	9.177	0.195	
37.2	1.53	1.381	7.052	0.196	
24.2	1.23	1.109	5.688	0.195	
13.4	0.92	0.827	4.232	0.195	
mean C _e				0.195	
Class				4	



APPENDIX: A MANUFACTURER'S DRAWING



<p>Seng Yoon Seng Holdings Sdn. Bhd. No. 46, Jalan Industri PBP 3, Taman Industri Pusat Bandar Puchong, 47100 Puchong, Selangor Darul Ehsan.</p> <p>Tel: 03 - 5882 5086 Fax: 03 - 5882 5209</p>	<p>DRAWING TITLE: LV3575</p>	<p>PROJECT: BSRIA Certification</p>
---	---	--

Note: Nominal pitch is 110mm but was reduced slightly for test sample purposes.