

Certificate

Certificate No: 55644/1

Issue No: 1 Date of issue: 15 November 2011

BSRIA Ltd has Type Tested the emergency smoke ventilator described below in accordance with the test methods contained within BS EN12101-3: 2002, Clauses 5 and 6.1 to 6.7 and has determined that the item met the requirements of the standard for the time and temperature classes listed.

Date of Test	23/09/11
BSRIA Test Item Number	55644A1AF

Ventilator Details

Ventilator Manufacturer	Ventispecial
Ventilator Model	CPC 220 S - (This unit also marketed under the names "Cyclone CPV 40" "PV 220 S" and "CJF 40 F")
Ventilator Serial Number	No serial number supplied

Motor Details

Motor Manufacturer	Weg
Motor Model	3-80-08/04, 0.8 kW
Motor Serial Number	1008981806

Test Conditions

BS EN 12101-3 Test Class	F300
Test Temperature	300
Test Time (Hours)	1 hr
Application Classes	Un-insulated Smoke reservoir Dual purpose No ducted cooling air required
Test Set-up	Horizontal Immersed Form A (air over motor-impeller)

Certificate Details

Client	Ventispecial BV
Client Address	Cartografenweg 26, 5141 NT WAALWIJK, Netherlands
Date of issue	15 November 2011
Date of expiry	15 November 2014

Quality Approved Mark Roper
Senior Test Engineer

Full details are shown in BSRIA Report Number 55644/1 available from the client.
To authenticate this certificate, visit www.bsria.co.uk/certificates, or contact BSRIA Limited.

This certificate relates to type testing and does not imply BSRIA's endorsement, approval, certification or on-going control of the product(s), either in terms of performance, design, manufacture or materials used. This certificate and the results stated herein relate solely to the sample product(s) tested and to the specific tests undertaken. The certificate will remain valid for the stated period providing no changes are made to the product, production method etc. This certificate is only valid when an electronic copy is also displayed at www.bsria.co.uk/certificates or contact BSRIA Ltd for confirmation. This certificate must not be reproduced except in full without the written approval of an executive director of BSRIA. It is only intended to be used within the context described in the text